

Handled by, department
Marina C Andersson, kb
Fire Technology
+46 10 516 52 92, marina.andersson@sp.se

Tarkett AB
Box 3004
372 81 RONNEBY

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to the product "iQ Optima" in accordance with the procedure given in EN 13501-1:2007.

2 Details of classified product

2.1 General

The product "iQ Optima" is defined as a resilient floor covering. Its classification is valid for the end use application as floor covering for indoor use.

According to the owner of this classification report, this product complies with the European product specification EN 14041:2004.

2.2 Product description

The product, "iQ Optima", is fully described below.

According to the client: Homogeneous vinyl flooring, with organic content consisting of polyvinylchloride, plasticizer, stabilizer and with a surface of PU-coating. The nominal area weight is 2.8 kg/m² and the nominal thickness is 2.0 mm.

3 Test reports & test results in support of classification

3.1 Test reports

This classification is based on the test report listed below:

Name of laboratory	Name of sponsor	Test report ref no	Accredited test method
SP	Tarkett AB	P900035	EN ISO 9239-1 EN ISO 11925-2

SP Technical Research Institute of Sweden

Postal address
SP
Box 857
SE-501 15 Borås
SWEDEN

Office location
Västeråsen
Brinellgatan 4
SE-504 62 Borås
SWEDEN

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

3.2 Test results

Test method	Parameter	Number of tests	Results	
			Continuous parameter mean (m)	Compliance parameter
EN ISO 11925-2		6		
15 s exposure	$F_s \leq 150$ mm		(-)	Compliant
EN ISO 9239-1		4		
	<i>Critical flux</i> (kW/m ²)		8.8	Compliant
	<i>Smoke</i> (%.min)		261	Compliant

(-) : not applicable

4 Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 12 and 15 of EN 13501-1:2007.

4.2 Classification

The product called “iQ Optima” in relation to its reaction to fire behaviour is classified:

B_0

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production	
B_0	-	s	1

Reaction to fire classification: B_0-s1

4.3 Field of application:

This classification is valid for the following product parameters:

Nominal thickness: 2.0 mm.

Nominal area weight: 2.8 kg/m².

This classification is valid for the following end use applications:

Substrates

- Wood based substrates or substrates of Euroclass A1_{fl} or A2_{fl} having a density ≥ 510 kg/m³.

The sample was delivered by the client. SP Fire Technology was not involved in the sampling procedure.

5 Limitations

This classification document does not represent type approval or certification of the product.

SP Technical Research Institute of Sweden
Fire Technology - Fire Dynamics



Per Thureson
Technical Manager



Marina C Andersson
Technical Officer